

**ILA REPORT**

**INDUSTRIAL LAB ANALYSIS, INC.**  
2240 Williamsburg Drive  
Glen Dale, WV 26038  
304-233-5595

**Approved By: IM/BM**

<b>Company: Century Mining</b> <b>Pit Identification: Sewage Treatment Plant</b> <b>Sampling Point: 601 STP Effluent</b> <b>Sample Collected By: BD</b> <b>Time &amp; Date Collected: 10-25-06 @ 1130</b>	<b>Sample No.: 06-10-1084</b> <b>Date Received: 10-25-06</b> <b>Date Reported: 11-10-06</b> <b>Analyzed By: IM/BM</b>
---	--

<b>Parameter</b>	<b>Result</b>	<b>Units</b>	<b>M D L</b>	<b>Ref MC</b>	<b>Preservative</b>
C BOD <sub>5</sub> Day	< 5.0	mg/l	5.0	405.1	None
T S S	1.0	mg/l	2.0	160.2	None
Ammonia	0.84	mg/l	0.5	350.2	H <sub>2</sub> SO <sub>4</sub>

Ref. MC: Standard Methods for Examination of Water and Wastewater, 18<sup>th</sup> Edition, and  
US EPA Methods for Chemical Analysis of Water and Waste.